



FLEXIBLE VEHICLE CROSSOVER CONSTRUCTION				
LAYER	CLAUSE	MATERIAL	BINDER	THICKNESS
Surface Course	CC 202 Cl.19.3	AC6 Dense Surf, Minimum PSV 55	100/150	25mm
Binder Course	CC 202 Cl.19.3	AC20 Dense Bin	100/150	50mm
Base	CC 202 Cl.19.3	AC32 Dense Base	40/60	70mm
Sub-Base	CC 201 Cl. 8	Type 1 Granular	N/A	150mm

RESIDENTIAL VEHICLE CROSSING ASPHALT



VEHICLE CROSSING DETAIL

NOTES

1. All dimensions in millimetres unless shown otherwise.
2. For kerbing details - See MKCC-1100-003.
3. Maximum crossfall to be 1:12. This is to be used at crossing points or over short sections.
4. Any stop tap boxes sited within the area of vehicle crossing specification are to be BS5834 PT2 heavy duty.
5. For further information refer to Standard Detail Guidance Note drawing no. MKCC-100-001.



Highways and Transportation
Civic Offices
1 Saxon Gate East
Central Milton Keynes
MK9 3EJ

DRAWING TITLE: Footway Vehicle Crossing Detail												
SCALE: NTS	REV: P01	DRAWN: PG	CHECKED: JM	APPROVED: LS	REV:	AMENDMENTS:	DRN:	CHCK'D:	APPR'D:	DATE:		
		INITIALS:			DRAWING NO: MKCC-1100-015							
		DATE:	17/02/2026	17/03/2026	17/03/2026							

